

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 016/2025

Date: 11 Feb 2025

It is certified that an inspection team headed by Mr. Deepak Shukla
(Executive Officer) (Name of Officers
with designation) from Municipal Corpn. Khatima (Name of
Department/Office) inspected the R.L.K. Sr. Secondary, Kapoor
Colony, Melaghat Road, Khatima (U.S. Nagar) (Name & Address of
the School) on 11/02/2025 and found that the R.L.K. Sr. Secondary
School, Kapoor Colony, Melaghat Road, Khatima (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of Five Years.

Signature with Seal :

Name

Designation

अधिसासी अधिकारी
नगरपालिका परिषद खटीमा
(रुधम सिंह नगर)
Executive Officer

To

The Manager
R.L.K. Sr. Sec. School
Kapoor Colony, Melaghat Road, Khatima
(Name & Address of the Institution)



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Rudrapur U.S.Nagar

E-mail: eeudmujs@gmail.com

Test Report ID: 121/UJS/USNDWQTML/2024-25

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	R L K Junior High School Melaghat Road ,Khatima U S Nagar		
Type of Source (Surface Water/ Ground Water/ Sub-Surface Water)	Sample Description:Ground Water		One water Sample Submitted from Submersible
Reference Sample Identification:	DLWQTML/UJS/RLK-01		Date of Start of Analysis: 13.02.2025
			Date of End of Analysis: 13.02.2025
Date of Sample Received: 13.02.2025		Sample Collected by:	Customer

S.No.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)
1	Colour	Less than 5	5	15
2	Total Dissolved Solids (TDS), mg/l max	263	500	2000
3	pH at 25°C	7.59	6.5 to 8.5	No Relaxation
4	Turbidity, NTU max	0.69	1	5
5	Chloride, Mg/l max	5.99	250	1000
6	Total Alkalinity as CaCO ₃ mg/l max	144	200	600
7	Total Hardness as CaCO ₃ mg/l max	200	200	600
8	Calcium as Ca mg/l max	40	75	200
9	Magnesium as Mg mg/l max	24.3	30	100
Microbiological Test Parameters				
10	E.Coli MPN /100ml	Absent	Absent	Absent
11	Total Coliform/100ml	Absent	Absent	Absent

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Chemist

Technical Manager/Lab Incharge

-End of Report -